



A P P R O V A L S ®

Certificate of Approval

Certificate No.: SAA120800

Date of Issue: 4 May 2012

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

Certificate Holder: InfluxGreen Energy Pte Ltd.
1, Goldhill Plaza,
#03-35/37 Podium Block,
Singapore 308899

Class Description: Non-Declared
Product Description: Grid-connected PV Inverter
Brand Name: InfluxGreen
Model No.: IGSI-5000DJ
Markings: Input: 100-450Vdc, Max 500Vdc,
2xMax 15.0A IP65
Output: 230V~ 50Hz 4950W, Max 25A
Standard: AS 4777.2:2005
AS 4777.3:2005
AS/NZS 3100:2009 Inc A1
Conditions: Nil


Approval Mark: SAA120800

Date First Registered: 4 May 2012
Date of Expiry: 11 October 2016


For and on Behalf of
SAA Approvals Pty Ltd



JAS-ANZ





APPROVALS®

Certificate of Approval

Addendum

Certificate No.: SAA120800

Date of Issue: 4 May 2012

Class Description: Non-Declared
Product Description: Grid-connected PV Inverter

Additional Models

IGSI-4000DJ

IGSI-3300DJ

Description

Similar to IGSI-5000DJ except rated input 2×Max 13.0A and rated output 4000W, Max 20A.

Similar to IGSI-5000DJ except rated input 2×Max 10.0A and rated output 3300W, Max 16.5A.

For and on Behalf of
SAA Approvals Pty Ltd



SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

