



APPROVALS®

## Certificate of Approval

**Certificate No.:** SAA120801

**Date of Issue:** 4 May 2012

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

**Certificate Holder:** InfluxGreen Energy Pte Ltd.  
1, Goldhill Plaza,  
#03-35/37 Podium Block,  
Singapore 308899

**Class Description:** Non-Declared  
**Product Description:** Grid-Connected PV Inverter  
**Brand Name:** InfluxGreen  
**Model No.:** IGSI-3000SJ  
**Markings:** Input: 100-500Vdc, 20A Max Class I IP65  
Output: 230Vac 50Hz 13A 3000W  
**Standard:** AS 4777.2:2005  
AS 4777.3:2005  
AS/NZS 3100:2009 Inc A1  
**Conditions:** Nil

**Approval Mark:** SAA120801

**Date First Registered:** 4 May 2012  
**Date of Expiry:** 31 January 2016

*Gina*

For and on Behalf of  
SAA Approvals Pty Ltd



JAS-ANZ

