



## Certificate of Approval

**Certificate No.:** SAA120802

**Date of Issue:** 4 May 2012

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

**Certificate Holder:** InfluxGreen Energy Pte Ltd.  
1, Goldhill Plaza,  
#03-35/37 Podium Block,  
Singapore 308899

**Class Description:** Non-Declared  
**Product Description:** Grid-connected PV Inverter  
**Brand Name:** InfluxGreen  
**Model No.:** IGSI-12000DJ  
**Markings:** Input: 250-1000Vdc MPPT: 250-800Vdc,  
Max 2x24A -25°C to +60°C Class I IP65  
Output: 400V 3/PE/N 50Hz 12kW,  
Max 3x19.4A  
**Standard:** AS 4777.2:2005  
AS 4777.3:2005  
AS/NZS 3100:2009 Inc A1  
**Conditions:** Nil

**Approval Mark:** SAA120802

**Date First Registered:** 4 May 2012  
**Date of Expiry:** 12 April 2017

A handwritten signature in dark ink, appearing to read 'Gina', is written over a horizontal line.

For and on Behalf of  
SAA Approvals Pty Ltd





APPROVALS®

## Certificate of Approval

**\*Addendum\***

**Certificate No.:** SAA120802

**Date of Issue:** 4 May 2012

**Class Description:** Non-Declared  
**Product Description:** Grid-connected PV Inverter

**Additional Models**  
IGSI-10000DJ

**Description**

Similar to IGSI-12000DJ except rated input 2×Max 22.0A and rated output 10kW, Max 3×16.2A.

A handwritten signature in dark ink, appearing to read 'Gina', is written over a horizontal line.

For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

JAS-ANZ

