



APPROVALS®

Certificate of Approval

Certificate No.: SAA120804

Date of Issue: 4 May 2012

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

Certificate Holder: InfluxGreen Energy Pte Ltd.
1, Goldhill Plaza,
#03-35/37 Podium Block,
Singapore 308899

Class Description: Non-Declared
Product Description: Grid-connected PV Inverter
Brand Name: InfluxGreen
Model No.: IGSI-1500SJ
Markings: Input: 100-450Vdc, Max 10A
-25°C to 60°C Class I IP65
Output: 230Vac 50Hz, Max 7.9A
Standard: AS 4777.2:2005
AS 4777.3:2005
AS/NZS 3100:2009 Inc A1
Conditions: Nil

Approval Mark: SAA120804

Date First Registered: 4 May 2012
Date of Expiry: 28 April 2016


For and on Behalf of
SAA Approvals Pty Ltd



JAS-ANZ

